

# DECLARATION OF PERFORMANCE

according to Annex III of the Regulation (EU) Nr. 305/2011 (Construction Products Regulation)

## Hilti Firestop Sleeve CFS-SL GA

No. Hilti CFS-SL GA

**1. Unique identification code of the product-type:**

Hilti Firestop Sleeve CFS-SL GA

**2. Intended use:**

Fire Stopping and Sealing Product for Penetration Seals, see ETA-20/1234 (20.12.2020)

Cable and conduit penetrations	Cables, Cable bundles, Conduits and Conduit bundles
--------------------------------	-----------------------------------------------------

**3. Manufacturer:**

Hilti Corporation, Feldkircherstrasse 100, 9494 Schaan, Principality of Liechtenstein

**4. System of AVCP:**

System 1

**5. European Assessment Document:**

EAD 350454-00-1104 "Fire stopping and fire sealing products – Penetration seals"

**European Technical Assessment:**

ETA-20/1234 (20.12.2020)

**Technical Assessment Body:**

ETA-Danmark A/S

**Notified body/s:**

MPA-Braunschweig, No. 0761

**6. Declared performance:**

Essential characteristic	Declared performance / Harmonised technical specification
Reaction to fire	Class E according to EN 13501-1.
Resistance to fire	Resistance to fire performance and field of application in accordance with EN 13501-2. See ETA-20/1234 (20.12.2020)
Air permeability	Tested according to EN 1026, See ETA-20/1234 (20.12.2020)
Durability and Serviceability	Z <sub>2</sub> according EAD 350454-00-1104. Clause 2.2.9.3.1.
Dangerous Substances	See ETA-20/1234 (20.12.2020)

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:



Stefan Juli  
Product Manager  
Business Unit Fire Protection  
Hilti Corporation



Martin Althof  
Head of Quality  
Business Unit Fire Protection  
Hilti Corporation