

DoC N° 52

DECLARATION OF CONFORMITY

1. Manufacturer:

ISEO Serrature S.p.A. - Via S. Girolamo, 13 – IT 25055 - Pisogne (BS)

2. Product identification:

Panic and emergency exit devices

Serie: **IDEA Base, IDEA Bolt, Push, Push SIRENA, Push-Bolt, Push-Bar, Pad, Pad-Bolt, Pro Exit, Pro4rm, IDEA Base infilare, Palmo, Push Infilare, Push Palmo, Pad Infilare, Trim Tronic, Trim**

Except PVD finishing

Marking on the product



3. Reference standard:

ISO 22196:2011 - Measurement of antibacterial activity on plastics and other non-porous surfaces

4. Test laboratory:

VisMederi S.r.l.
<https://www.vismederi.com>
 Strada del Petriccio e Belriguardo, 35
 53100 Siena, Italy

Università degli Studi di Padova
 Dipartimento di medicina molecolare
 Via A. Gabelli 63
 35121 Padova, Italy

5. Test reports

Number	Issuing date	Issued by:	Description	Bacteria (¹)	Result
2100134.09	2021_11_16	VisMederi	Paint on steel base	① ②	Positive
2100134.08	2021_11_16	VisMederi	Paint on plastic base	① ②	Positive
2100134.07	2021_11_16	VisMederi	Paint on aluminium base	① ②	Positive
2100134.05	2021_11_16	VisMederi	Paint on aluminium base	① ②	Positive
2100134.04	2021_11_16	VisMederi	Paint on zamak base	① ②	Positive
2100134.03	2021_11_16	VisMederi	Paint on steel base	① ②	Positive
2100134.02	2021_11_16	VisMederi	Paint on aluminium base	① ②	Positive
2100134.01	2021_11_16	VisMederi	Paint on zamak base	① ②	Positive
2761	2012_11_16	University of Padua	Paint on steel base	① ② ③ ④ ⑤ ⑥	Positive

(¹) Bacteria tested

- ① Escherichia coli ATCC 8739, ② Staphylococcus aureus ATCC 6538P,
- ③ Legionella pneumophila ATCC 33152, ④ Salmonella enteritidis ATCC 13076,
- ⑤ Listeria monocytogenes ATCC 35152, ⑥ MRSA ATCC 43300

6. Declaration

The items described in 2) are in compliance with the standards and the results described in 3) and 5)

ISEO SERRATURE S.p.A.
Stefano Gelmini
 Product Certification Manager

Place	First issuing	Current issuing
PISOGNE (BS) ITALY	16/11/2021	16/11/2021