

Kitemark™ Certificate

This is to certify that:

Mobiak S.A.
M. Mpotsari 96-98
Chania Crete
73136
Greece

Holds Certificate Number:

KM 705999

In respect of:

BS EN 3
Portable fire extinguishers

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:

Shahm Barhom, Group Product Certification Director

First Issued: 2019-10-09

Latest Issue: 2024-08-08

Effective Date: 2024-08-08

Expiry Date: 2027-07-01

Page: 1 of 2



Kitemark™ Certificate

No. KM 705999

Model No	Description	GAD Drawing Reference, Revision & Date	Technical File Review
MBK22-LITHIUM-HGEL-6	6 litre, water based (HydroGel BM 048), stored pressure. Temperature range: 5°C to 60°C Working pressure: 15 bar Average discharge duration: 34.45 s Fire ratings: 13A & 25F	MBK6LT-SP-EXT/HYGEL, Revision 0 dated 2023-01-11	30102262
MBK22-LITHIUM-HGEL-9	9 litre, water based (HydroGel BM 048), stored pressure. Temperature range: 5°C to 60°C Working pressure: 15 bar Average discharge duration: 57.35 s Fire rating: 21A	MBK9LT-SP-EXT/HYGEL, Revision 0 dated 2023-04-25	30102262
MBK19-020CA-P1D	2 kg carbon dioxide, steel cylinder with side exit horn. Temperature range: -20°C to 60°C Average discharge duration: 9.42 s Fire rating: 34B	JXMT/2-180, Revision 1 dated 2020-04-30	9714392 and 30102262
MBK06-020CA-P1D	2 kg carbon dioxide, steel cylinder with front exit horn. Temperature range: -20°C to 60°C Average discharge duration: 8.07 s Fire rating: 34B	JXMT/2-162, Revision 2 dated 2020-04-06	9714392 and 30102262
MBK19-050CA-P1D	5 kg carbon dioxide, steel cylinder. Temperature range: -20°C to 60°C Average discharge duration: 11.18 s Fire rating: 89B	JXMT/5-159, Revision 1 dated 2019-07-11	9714392

All the above products are certified to BS EN 3-7:2004+A1:2007

Suitability for li-ion fire types is outside the scope of this certification

First Issued: 2019-10-09

Latest Issue: 2024-08-08

Effective Date: 2024-08-08

Expiry Date: 2027-07-01

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).