



EVPÚ[®]



CERTIFICATE No. 00019/101/1/2020

on April 17th, 2020

Certification body of EVPÚ a.s. confirms the compliance of the products with requirements of undermentioned standards.

Product: **Conventional Fire Panel**

Type: **Matrix2000**

Derived variants: **Matrix2004R00TO, Matrix2004R04TO, Matrix2008R00TO, Matrix2008R08TO, Matrix2012R00TO, Matrix2012R04TO, Matrix2012R08TO, Matrix2012R12TO, Matrix2016R00TO, Matrix2016R08TO, Matrix2016R16TO, Matrix2020R00TO, Matrix2020R04TO, Matrix2020R08TO, Matrix2020R12TO, Matrix2020R16TO, Matrix2020R20TO, Matrix2024R00TO, Matrix2024R08TO, Matrix2024R16TO, Matrix2024R24TO**

Specification: **220-240 VAC, 50/60 Hz, 1A**

Client/Manufacturer: **PARADOX HELLAS S.A. - OIKONOMIDIS P. SECURITY SYSTEMS S.A.**
3 Korinthou str., Metamorfosi, 14451 Attiki, Greece

Manufacturing facility: **PARADOX HELLAS S.A. - OIKONOMIDIS P. SECURITY SYSTEMS S.A.**
69th Klm of N.R. Athens - Lamia, 32009 Vrises Ritsonas, Greece

Standards: **EN 62368-1: 2014 + A11: 2017,**
EN 55032: 2015,
EN 61000-3-2: 2014,
EN 61000-3-3: 2013 + A1: 2019,
EN 50130-4: 2011 + A1: 2014,
EN 54-2: 1997 + AC: 1999 + A1: 2006 Clause 15.8

Results of tests of mentioned products are summarized in Final report on assessment No. **0-0068/20/C** of **April 17th, 2020**.

Used standards are harmonized with directives of the European parliament and of the Council 2014/35/EU transposed into Slovak government decree No. 148/2016 Z. z. and 2014/30/EU transposed into Slovak government decree No. 127/2016 Z. z.

Validity of certificate is limited for the period
from: **April 17th, 2020**
until: **April 16th, 2023**




Marek H u d á k

Any significant changes in the design or construction of the products or amendments of the technical decrees reference above may render this Certificate invalid. The product liability rests with the manufacturer or his representative.

053520