



EVPÜ[®]



CERTIFICATE No. 00098/101/1/2021 on November 25th, 2021

Certification body of EVPÜ a.s. confirms the compliance of the products with requirements of undermentioned standards.

Product: **Advaced Conventional Fire Alarm Control Panel**

Type: **NEON 8, NEON 4, NEON 2**

Specification: **230VAC, 50Hz, 1A**

Client/Manufacturer: **PARADOX HELLAS S.A. - OIKONOMIDIS P. SECURITY SYSTEMS S.A.,
3 Korinthou str., 14451 Metamorfos, Attiki, Greece**

Identification Code: **EL094517180**


Manufacturing facilities: **PARADOX HELLAS S.A. - OIKONOMIDIS P. SECURITY SYSTEMS S.A.,
69th Klm of N.R.Athens – Lamia, 32009 Vrises Ritsonas, Avlida, Greece**

Standards: **EN 62368-1: 2020 + A11: 2020,
EN 55032: 2015 + A1: 2020 + A11: 2020,
EN IEC 61000-3-2: 2019 + A1: 2021,
EN 61000-3-3: 2013 + A1: 2019,
EN 50130-4: 2011 + A1: 2014**

Results of tests of mentioned products are summarized in Final report on assessment No. **0-0365/21/C** of **November 25th, 2021**.

Used standards are harmonized with directives of the European parliament and of the Council 2014/35/EU transposed into Slovak government decree No. 148/2016 Z. z. and 2014/30/EU transposed into Slovak government decree No. 127/2016 Z. z.

Validity of certificate
is limited for the period
from: **November 25th, 2021**
until: **November 24th, 2024**



Michal Mišiak

Any significant changes in the design or construction of the products or amendments of the technical decrees reference above may render this Certificate invalid. The product liability rests with the manufacturer or his representative.

054189

EVPÜ a.s., Trenčianska 19, 018 51 Nová Dubnica, Slovak republic, www.evpu.sk