

Kitemark™ Certificate

This is to certify that:

Olympia Electronics
N. Lakasas - P. Arvanitidis S.A.
72nd klm Old Highway
Thessaloniki Katerini
Eginio, Pieria
P.C 60300
Greece

Holds Certificate Number:

KM 640081

In respect of:

BS EN 60598-2-22
Emergency luminaires

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:

Shahm Barhom, Group Product Certification Director

First Issued: 2016-01-14

Latest Issue: 2023-06-21

Effective Date: 2023-06-21

Expiry Date: 2025-01-18



Page: 1 of 41

Kitemark™ Certificate

No. KM 640081

Emergency Luminaires to BS EN 60598-2-22:2014 and BS EN 60598-1:2015+A1:2018.

Skyline range of emergency exit luminaires

Rated: 220-240 V, 50/60 Hz, Class II, IP65

BSI Test Report reference 3225066-1 and 9787475

Model	Rating	Duration	IP	Assembly type
SLL-501/WP	220-240 V Class II 50/60 Hz	1.5 hours	IP65	Surface mounted emergency exit luminaire
SLL-503/WP	220-240 V Class II 50/60 Hz	3 hours	IP65	Surface mounted emergency exit luminaire
SLL-501/WP/ADR	220-240 V Class II 50/60 Hz	1.5 hours	IP65	Surface mounted emergency exit luminaire
SLL-503/WP/ADR	220-240 V Class II 50/60 Hz	3 hours	IP65	Surface mounted emergency exit luminaire
SLL-503/LS	220-240 V Class II 50/60 Hz	3 hours	IP40	Surface mounted emergency exit luminaire
SLL-503/LS/WP	220-240 V Class II 50/60 Hz	3 hours	IP40	Surface mounted emergency exit luminaire
SLL-503	220-240 V Class II 50/60 Hz	3 hours	IP40	Surface mounted emergency exit luminaire
SLL-503/ADR	220-240 V Class II 50/60 Hz	3 hours	IP40	Surface mounted emergency exit luminaire
SLL-501	220-240 V Class II 50/60 Hz	1.5 hours	IP40	Surface mounted emergency exit luminaire
SLL-501/ADR	220-240 V Class II 50/60 Hz	1.5 hours	IP40	Surface mounted emergency exit luminaire

First Issued: 2016-01-14

Latest Issue: 2023-06-21

Effective Date: 2023-06-21

Expiry Date: 2025-01-18

Page: 6 of 41

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Kitemark™ Certificate

No. KM 640081

Emergency Luminaires to BS EN 60598-2-22:2014 and BS EN 60598-1:2015+A1:2018.

Skyline range of emergency exit luminaires

Rated: 220-240 V, 50/60 Hz, Class II, IP65

BSI Test Report reference 3225066-1 and 9787475

Model	Rating	Duration	IP	Assembly type
FRN SLL-501/WP	220-240 V Class II 50/60 Hz	1.5 hours	IP65	Surface mounted emergency exit luminaire
FRN SLL-503/WP	220-240 V Class II 50/60 Hz	3 hours	IP65	Surface mounted emergency exit luminaire
FRN SLL-501/WP/ADR	220-240 V Class II 50/60 Hz	1.5 hours	IP65	Surface mounted emergency exit luminaire
FRN SLL-503/WP/ADR	220-240 V Class II 50/60 Hz	3 hours	IP65	Surface mounted emergency exit luminaire
FRN SLL-503/LS	220-240 V Class II 50/60 Hz	3 hours	IP40	Surface mounted emergency exit luminaire
FRN SLL-503/LS/WP	220-240 V Class II 50/60 Hz	3 hours	IP40	Surface mounted emergency exit luminaire
FRN SLL-503	220-240 V Class II 50/60 Hz	3 hours	IP40	Surface mounted emergency exit luminaire
FRN SLL-503/ADR	220-240 V Class II 50/60 Hz	3 hours	IP40	Surface mounted emergency exit luminaire
FRN SLL-501	220-240 V Class II 50/60 Hz	1.5 hours	IP40	Surface mounted emergency exit luminaire
FRN SLL-501/ADR	220-240 V Class II 50/60 Hz	1.5 hours	IP40	Surface mounted emergency exit luminaire

First Issued: 2016-01-14

Latest Issue: 2023-06-21

Effective Date: 2023-06-21

Expiry Date: 2025-01-18

Page: 26 of 41

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).