



EVPÜ[®]

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0545

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011* (the Construction products Regulation or CPR), this certificate applies to the construction product

Conventional fire alarm manual call point **SensoMAG MCP50**

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

Teletek Electronics JSC
14A Srebarna Str., 1407 Sofia, Bulgaria

and produced in the manufacturing plant

Teletek Electronics JSC
14A Srebarna Str., 1407 Sofia, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-11:2001

EN 54-11:2001/A1:2005

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.


This certificate was first issued on April 11th, 2017 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Nová Dubnica, April 11th, 2017

053087

EVPÜ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk
Page 1 / 2 FCO 425-13 Rev.1


Marek Hudák
Director NB

Annex to Certificate No. 1293 - CPR – 0545 from April 11th, 2017

Technical Specifications

SensoMAG MCP50 is a manual call point, designed to work with conventional fire panels in stay-by mode, the resettable (flexible) call point element is in a middle position. The call point is powered off and the LED is off. When pressed on, the resettable element is moving down and a color strip is shown on at its upper side. The call point is powered on and the LED is on-this is a "Fire alarm" condition. The resetting of the flexible element back in stay-by mode is done with the special key tool-fix the long side of the tool at the call point bottom side and push up until flexible element moves up in middle position(a click is heard).

Products parameters:

Operating voltage:	9-30VDC
Nominal operating voltage:	24VDC
Current consumption	in alarm state: 23mA/15V, 38mA/24V, 48mA/30V
Operating temperature:	10°C ÷ +40°C
Relative humidity:	≤ 93% @ +40°C
Material (plastic), colour:	ABS, red
Degree of protection:	IP40
Dimensions:	90x56x90mm
Weight:	150g

Essential characteristics	Test specification	Harmonised technical specifications	Performance
Nominal activation conditions / Sensitivity and Performance under fire conditions	cl. 4.3.2, 4.4, 4.7.1, 4.7.4=N/A, 5.2, 5.3	EN 54-11:2001 EN 54-11:2001/A1:2005	Pass
Operational reliability	cl. 4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8=N/A, 5.4, 5.5	EN 54-11:2001 EN 54-11:2001/A1:2005	Pass
Durability of operational reliability: temperature resistance	cl. 5.7, 5.8=N/A, 5.9	EN 54-11:2001 EN 54-11:2001/A1:2005	Pass
Durability of operational reliability: vibration resistance	cl. 5.14 to 5.17	EN 54-11:2001 EN 54-11:2001/A1:2005	Pass
Durability of operational reliability: humidity resistance	cl. 5.10, 5.11=N/A, 5.12, 5.19=N/A	EN 54-11:2001 EN 54-11:2001/A1:2005	Pass
Durability of operational reliability: corrosion resistance	cl. 5.11=N/A, 5.13	EN 54-11:2001 EN 54-11:2001/A1:2005	Pass
Durability of operational reliability: electrical stability	cl. 5.6, 5.18	EN 54-11:2001 EN 54-11:2001/A1:2005	Pass



Nová Dubnica, April 11th, 2017


 Marek Hudák
 Director NB